

GOA STATE POLLUTION CONTROL BOARD

गोंय राज्य प्रदूषण नियंत्रण मंडळ

(An ISO 9001-2015, ISO 14001:2015. OHSAS 18001:2007 Certified Board)

Phone Nos. : 0832-2407700
2407701, 2407702
2407703

Tel/Fax No. : 0832-2407700



Email Ids:
Chairman, GSPCB: chairman-gspcb.goa@nic.in
Member Secretary GSPCB: ms-gspcb.goa@nic.in
Environment Engineer, GSPCB: ee-gspcb.goa.nic.in
Scientist, GSPCB: scientist-gspcb.goa@nic.in
Office: goapcb@gspcb.in

No: No. 1/27/01-PCB/Tech/14862

Date: 16/11/2020

NOTICE INVITING QUOTATION

Sub: Quotation to carry out "Electrical point wiring with accessories in laboratory of Goa state Pollution Control Board"

Sealed quotations are invited from the interested agencies by the Goa State Pollution Control Board to carry out "Electrical point wiring with accessories in laboratory of Goa State Pollution Control Board at saligao Goa". The contractors shall indicate the rates in figures as well as in words. The sealed cover shall be superscribed as "Electrical point wiring with accessories in laboratory of Goa state Pollution Control Board" The detail of the item description along with quantities for the said work is enclosed herewith for your reference.

The contractors/agencies who are interested may inspect the site before quoting for the same. The sealed quotations shall be received upto 20/11/2020 at 17:00 hours and shall be opened on 23/11/2020 at 15:30 hours in the office of Goa State Pollution Control Board Saligao and in the presence of the agency/contractors representatives who may like to be present.

The quoted rates shall be inclusive of delivery of material and test reports to Goa State Pollution Control Board. etc.,. No extra claim shall be entertained in this connection.

On satisfactory completion of work, final bill duly pre-receipted on revenue stamp along with copy of PAN Card shall be submitted by you to the Goa State Pollution Control Board for effecting payment.

Yours faithfully,


Member Secretary
Goa State Pollution Control Board

Encl: As above

To,
Board Website

Copy to:

- 1) Account section, GSPCB
- 2) Office copy
- 3) Guard file

Sr.No.	Item of Work	Unit	Qty	Rate	Amount
	POINT WIRING WITH MODULAR ACCESSORIES.				
1	Supplying and fixing suitable size modular GI box with modular plate and cover in front on surface or in recess including providing and fixing 3 pin 5/6 A modular socket outlet and 5/6 A modular switch connection painting etc. as required.				
a)	(a) Cat A	No.	13		
2	Supplying and fixing suitable size modular GI box with modular plate and cover in front on surface or in recess including providing and fixing 6 pin 15/16 A and 5/6 A modular socket outlet modular socket outlet and 15/16 A modular switch connection painting etc. as required.				
a)	(a) Cat A	No.	10		
3	Supplying and fixing 25 A 240 V SPN industrial type socket outlet with 2 pole and earth metal enclosed plug top along with 25 A, C series SP MCB in sheet steel enclosure in surface or in recess with chained metal cover for the socket outlet and complete with connections testing and commissioning etc. as required.				
	(a) Cat A	Each	1		
4	Supplying and fixing 20 A 415 V TPN industrial type socket outlet with 4 pole and earth metal enclosed plug top along with 20 A, C series TP MCB in sheet steel enclosure in surface or in recess with chained metal cover for the socket outlet and complete with connections testing and commissioning etc. as required.				
	(a) Cat A	Each	4		
	MAINS, CIRCUITS				
5	Wiring for circuit / submain wiring along with earth wire with the following sizes of FR PVC Insulated copper conductor single core cable in the independent surface casing capping of appropriate size as required.				
a	2 x 10 sq.mm + 1 x 2.5 sq.mm earthwire	Metre	195		
b	2 x 6 sq.mm + 1 x 2.5 sq.mm earthwire	Metre	52		
c	4 x 4 sq.mm + 1 x 2.5 sq.mm earthwire	Metre	70		
6	Supply of 4 core armoured PVC insulated, PVC sheathed aluminium conductor cable of 1.1 KV grade with ISI mark conforming to IS:1554 (Part I), IS:7098 (Part II) with latest amendments of following size.				
a	4 Core: 25 sq.mm	Metre	55		
7	Laying of one number PVC insulated and PVC sheathed/XLPE power cable of 1.1 KV grade of size not exceeding 25 sq.mm on surface, etc. complete as required	Metre	55		
8	Supplying and making cable end terminations with brass compression gland and aluminium lugs for following sizes of 4 Core PVC insulated PVC sheathed/XLPE aluminium conductor cable of 1.1 KV grade, complete as required.				
a	(6) 4 x 25 Sq. mm.	Each	8		
	DISTRIBUTION BOARDS, MCB, MCCB & RCCB & PANELS				
9	Supplying and fixing following way SPN sheet steel MCB distribution board 240 V on surface/ recess complete with tinned copper busbar neutral busbar earth bar dinnbar detachable gland plate interconnections phosphotized and powder painted including earthing etc. as required (but without MCB / RCCB / Isolator).				
	12 way double door Cat A	Each	1		
10	Supplying and fixing following way TPN sheet steel, double door, Horizontal type MCB distribution board 415 V on surface/ recess complete with tinned copper busbar neutral busbar earth bar dinnbar detachable gland plate interconnections phosphotized and powder painted including earthing etc. as required. (but without MCB / RCCB / Isolator)				
a	6 way (8+18), double door, Horizontal type Cat A	Each	1		
b	8 way (8+24), double door, Horizontal type Cat A	Each	1		
11	Supplying and fixing 6 A to 32 A, C series MCB suitable for lighting and other loads of following poles in the existing MCB DB complete with connections testing and commissioning etc as required.				
a	SP, Cat A	Each	28		
b	TPN, Cat A	Each	2		
12	Supplying and fixing 40 A, C series MCB suitable for lighting and other loads of following poles in the existing MCB DB complete with connections testing and commissioning etc as required.				

Sr.No.	Item of Work	Unit	Qty	Rate	Amount
a	TPN, Cat A	Each	1		
13	Supplying and fixing 63 A, C series MCB suitable for lighting and other loads of following poles in the existing MCB DB complete with connections testing and commissioning etc as required.				
a	TPN, Cat A	Each	1		
14	Supplying and fixing following rating double pole (single pole and neutral) 240 V RCCB having a sensitivity current upto 300mA in the existing MCB DB complete with connections testing and commissioning etc as required				
a	40 A, Cat A	Each	7		
15	Supplying and fixing following rating four pole (triple pole and neutral) 415 V RCCB having a sensitivity current upto 300mA in the existing MCB DB complete with connections testing and commissioning etc as required				
a	40 A, Cat A	Each	2		
b	63 A, Cat A	Each	1		
	EARTHING				
16	Providing and fixing 25mm x 5mm GI strip on surface or in recess for connections etc. as required	Metre	80		
17	Labour charges towards modification of existing DB dressing including termination alterations at Switch sockets	Per DB	3		
	Total				
	Add GST @ 18%				
	Grand total				